



A DIVISION OF GETZ FIRE EQUIPMENT

**GETZ EQUIPMENT INNOVATORS**  
**PART NO.: 3G0179**  
**PIPE INTEGRITY TEST KIT**  
(Revised 9/18/19)



2320 Lakecrest Drive, Pekin IL 61554

PH. (888) 747-4389 • Fax (309) 495-0625

Website: [www.getzequipment.com](http://www.getzequipment.com)

## LIMITED WARRANTY

Products manufactured by Getz Equipment Innovators (with exception of electrical products or components) will be free from defects for a period of one year from shipment date. Electrical products and/or components used in manufactured products will have a (6) month warranty from shipment date. During the warranty period, customers who experience any manufacture-related service issues with our products, the product may be returned for repair or replacement. Customer must contact Getz Equipment for approval prior to any product return. Notwithstanding the foregoing, the limited warranty set forth shall be immediately void of customer uses any replacement parts other than those provided by Getz Equipment Innovators. The warranty does not cover normal wear and tear items, defects resulting from modification, alteration, misuse, exposure to corrosive conditions, extremely high temperatures, improper installation or maintenance. Warranties on component items not manufactured by Getz Equipment Innovators are provided by others whose warranty, evaluation and judgment will be final.

All implied warranties, including, but not limited to, warranties of fitness for purpose and merchantability, are limited to the time periods as stated above. In no event shall Getz Equipment Innovators be liable to incidental or consequential damages. Some states do not allow limitations on how long an implied warranty lasts or the exclusions or limitation of incidental or consequential damages, so that the above limitations or exclusions may not apply to you. Getz Equipment Innovators neither assumes nor authorizes any representative or other person to assume for it any obligation or liability other than as expressly set forth herein.

### **Mobile Service Vehicles:**

The warranty does not cover:

- Defects in the chassis and or power unit
- Defects in separately manufactured products not produced by Getz Equipment Innovators
- Deterioration due to normal wear, tear, and exposure
- Repairs made necessary by negligent use, misuse, abuse, loading the service vehicle beyond its gross vehicle weight limitations, accident, acts of God, or other contingencies beyond the control of Getz Equipment Innovators.
- Repairs deemed necessary by reason of the failure to follow ordinary maintenance procedures.
- Repairs deemed necessary by reason of alterations done without Getz Equipment Innovators' written approval.

Warranty Service:

- All warranty repairs will be performed by Getz Equipment Innovators in Pekin, IL, unless otherwise authorized by Getz Equipment Innovators.

Freight:

- Getz Equipment Innovators will not be liable for shipping or transportation charges to or from customer's location.

This warranty gives you specific legal rights, and you may also have other rights which vary from state to state. To obtain performance to the obligation of the warranty, write to Getz Equipment Innovators, 2320 Lakecrest Drive, Pekin IL 61554, USA for instructions.

**PIPE INTEGRITY TEST KIT**

**TABLE OF CONTENTS**

**PAGE #**

1 ..... DRAWING # 1  
2 ..... DRAWING #1 – PARTS LIST  
3 ..... OPERATING INSTRUCTIONS

DRAWING 1



## DRAWING 1 – PARTS LIST

ITEM NO.	PART NUMBER	DESCRIPTION	QTY.
1	1G0654	REGULATOR PRESET 150 PSI	1
2	1G51680	PIPE RDCR BELL 1/4 X 1/8	1
3	1G51654	PIPE NIP BR 1/8 CLOSE	1
4	1G0052	HOSE FLEX COIL BLUE 10 FT	1
5	3G0082	VALVE PUSH BUTON W/RED COVER	1
6	1G0655	CYLINDER 33 CUFT NITROGEN	1
7	60408	HOSE ANSUL ACTUATION SS 16"	1
8	1G0029	COUPLING FEMALE W/CHECK UNIT 1/4	1
9	1G0656	7/16-20 FLARE X 1/8 NPT	1
10	1G0661	GAUGE 0-3000	1
11	3G0184	1/2" PIPE NETWORK ADAPTER	1
12	3G0183	3/4" PIPE NETWORK ADAPTER	1
13	3G0185	ANSUL UNION ADAPTER	1
14	3G58637	3/8" PIPE NETWORK ADAPTER	1

## OPERATING INSTRUCTIONS

1. Disarm system per NFPA 17A and manufactures specification.
2. Disconnect all agent cylinder(s) and supply line(s).
3. Use correct adapter(s): 3/8"- 1" (item #11 - 14). (Note: 1" adapter sold separately). Install correct adapter at beginning of supply line(s) from system tank(s). Manifoldded supply lines will require additional adapters or reconfiguring manifoldded supply lines. (individual supply line).
4. Connect flexible tank hose quick coupler (item #8) to the appropriate adapter(s).
5. Open nitrogen tank valve completely.
6. Check gauge for tank pressure.
7. Depress red button (item #5) on tank of flexible hose. Regulated pressure will discharge at approximately 150 psi.
8. Hold red button minimum 2 seconds or until blow off caps are free from nozzles.  
**Note:** If any cap(s) did not release from nozzle, please refer to NFPA 17A and manufacturer's specifications.
9. Repeat steps 7 and 8 until all nozzles are in proper operating condition.
10. Close valve on nitrogen tank.
11. Depress red button (item #5) until all nitrogen has been discharged.
12. Disconnect quick coupler (item #8).
13. Remove adapter(s) (items #11 – 14).
14. Reinstall all piping and system components.
15. Reinstall all components needed to arm system.
16. Verify system is operational per NFPA 17A and manufactures specification.

**Note:** Part Number 1G0655, Nitrogen Cylinder 33 CUFT, maximum fill pressure is 2,216 PSI.

