

GETZ EQUIPMENT INNOVATORS PART # 3G59377 SUPERKAN RECOVERY SYSTEM



2320 Lakecrest Drive, Pekin, Illinois 61554 Telephone: 888-747-4389 Fax: 309-495-0625 Website: www.getzequipment.com

Limited Warranty

Products manufactured by Getz Equipment Innovators (with exception of electrical products or components) will be free from defects for a period of one year from shipment date. Electrical products and/or components used in manufactured products will have a (6) month warranty from shipment date. During the warranty period, customers who experience any manufacture-related service issues with our products, the product may be returned for repair or replacement. Customer must contact Getz Equipment for approval prior to any product return. Notwithstanding the foregoing, the limited warranty set forth shall be immediately void of customer uses any replacement parts other than those provided by Getz Equipment Innovators. The warranty does not cover normal wear and tear items, defects resulting from modification, alteration, misuse, exposure to corrosive conditions, extremely high temperatures, improper installation or maintenance. Warranties on component items not manufactured by Getz Equipment Innovators are provided by others whose warranty, evaluation and judgment will be final.

All implied warranties, including, but not limited to, warranties of fitness for purpose and merchantability, are limited to the time periods as stated above. In no event shall Getz Equipment Innovators be liable to incidental or consequential damages. Some states do not allow limitations on how long an implied warranty lasts or the exclusions or limitation of incidental or consequential damages, so that the above limitations or exclusions may not apply to you. Getz Equipment Innovators neither assumes nor authorizes any representative or other person to assume for it any obligation or liability other than as expressly set forth herein.

Mobile Service Vehicles:

The warranty does not cover:

- Defects in the chassis and or power unit
- Defects in separately manufactured products not produced by Getz Equipment Innovators
- Deterioration due to normal wear, tear, and exposure
- Repairs made necessary by negligent use, misuse, abuse, loading the service vehicle beyond its gross vehicle weight limitations, accident, acts of God, or other contingencies beyond the control of Getz Equipment Innovators.
- Repairs deemed necessary by reason of the failure to follow ordinary maintenance procedures.
- Repairs deemed necessary by reason of alterations done without Getz Equipment Innovators' written approval.

Warranty Service:

- All warranty repairs will be performed by Getz Equipment Innovators in Pekin, IL, unless otherwise authorized by Getz Equipment Innovators.
 Freight:
- Getz Equipment Innovators will not be liable for shipping or transportation charges to or from customer's location.

This warranty gives you specific legal rights, and you may also have other rights which vary from state to state. To obtain performance to the obligation of the warranty, write to Getz Equipment Innovators, 2320 Lakecrest Drive, Pekin IL 61554, USA for instructions.

OPERATING INSTRUCTIONS

DISCHARGING (30# max. capacity)

- 1. Remove the hose or nozzle from the extinguisher and install the proper adapter.
- 2. Secure the Superkan from falling over to prevent damage.
- 3. Place F-1 filter bag item (#4) over the fill tube.
- 4. Connect quick connect item (#7) to the extinguisher.
- 5. Pull the extinguisher safety pin and discharge the extinguisher into the Superkan. (Note: The Superkan is not designed as a storage container. All chemical should be removed before discharging the next extinguisher.)

RECHARGING

- 1. Remove the F-1 filter.
- 2. Connect item (#7) female quick connect to item (#8) male quick connect.
- 3. Invert the Superkan on top of the extinguisher. Allow chemical to completely empty into the extinguisher.
- 4. Replace the extinguisher valve and charge to the proper pressure.

