



**GETZ EQUIPMENT INNOVATORS
PART NUMBER: 3G59439
BUCKET ATTACHMENT**



2320 Lakecrest Drive, Pekin, Illinois 61554
Telephone: 888-747-4389 Fax: 309-495-0625
Website: www.getzequipment.com

Limited Warranty

Products manufactured by Getz Equipment Innovators (with exception of electrical products or components) will be free from defects for a period of one year from shipment date. Electrical products and/or components used in manufactured products will have a (6) month warranty from shipment date. During the warranty period, customers who experience any manufacture-related service issues with our products, the product may be returned for repair or replacement. Customer must contact Getz Equipment for approval prior to any product return. Notwithstanding the foregoing, the limited warranty set forth shall be immediately void of customer uses any replacement parts other than those provided by Getz Equipment Innovators. The warranty does not cover normal wear and tear items, defects resulting from modification, alteration, misuse, exposure to corrosive conditions, extremely high temperatures, improper installation or maintenance. Warranties on component items not manufactured by Getz Equipment Innovators are provided by others whose warranty, evaluation and judgment will be final.

All implied warranties, including, but not limited to, warranties of fitness for purpose and merchantability, are limited to the time periods as stated above. In no event shall Getz Equipment Innovators be liable to incidental or consequential damages. Some states do not allow limitations on how long an implied warranty lasts or the exclusions or limitation of incidental or consequential damages, so that the above limitations or exclusions may not apply to you. Getz Equipment Innovators neither assumes nor authorizes any representative or other person to assume for it any obligation or liability other than as expressly set forth herein.

Mobile Service Vehicles:

The warranty does not cover:

- Defects in the chassis and or power unit
- Defects in separately manufactured products not produced by Getz Equipment Innovators
- Deterioration due to normal wear, tear, and exposure
- Repairs made necessary by negligent use, misuse, abuse, loading the service vehicle beyond its gross vehicle weight limitations, accident, acts of God, or other contingencies beyond the control of Getz Equipment Innovators.
- Repairs deemed necessary by reason of the failure to follow ordinary maintenance procedures.
- Repairs deemed necessary by reason of alterations done without Getz Equipment Innovators' written approval.

Warranty Service:


- All warranty repairs will be performed by Getz Equipment Innovators in Pekin, IL, unless otherwise authorized by Getz Equipment Innovators.

Freight:

- Getz Equipment Innovators will not be liable for shipping or transportation charges to or from customer's location.

This warranty gives you specific legal rights, and you may also have other rights which vary from state to state. To obtain performance to the obligation of the warranty, write to Getz Equipment Innovators, 2320 Lakecrest Drive, Pekin IL 61554, USA for instructions.



PARTS LIST



ITEM NO	PART NO	DESCRIPTION	QTY
ITEM 1	1G0014	RING BRACKET	1
ITEM 2	1G0048	TUBING POLY 1/4 WHITE	1
ITEM 3	1G0101	CLAMP WORM GEAR S.S. 5/8	1
ITEM 4	1G0198	ELBOW 90 1/4" STEM TO 1/4" TUBE	3
ITEM 5	1G0264	ALUMINUM ANGLE -1 1/2 X 1 1/2 X 1/8	0.33
ITEM 6	1G53065	VALVE BALL 1/4 3 WAY BRACKET ATTACHMENT	1
ITEM 7	1G53293	CPVC TUBE 1/2 X 6	1.5
ITEM 8	3G58553	FILL LINE ASSEMBLY	1

INSTALLATION

1. Mount the aluminum angle to your existing control console by using the screws, washers and nuts included. To do so, you will need to remove the front cover from your control console to access the inside of the box. Drill the holes from the outside of the box and insert the screws. On the inside of the control console, slide the washers onto the screws and tighten with the nuts.



2. Disconnect your current fill line assembly from the port at the bottom of your control console and insert the airline coming out of the middle port on the bucket attachment 3 way valve. Connect your existing fill line assembly air line to the top port of the 3 way valve.




INSTALLATION CONTINUED

- Place the ring bracket (item 1) on the right side of the hopper stand at the same height as the existing ring bracket. Mark the holes on the hopper stand with a pencil or marker. Drill the holes with a 1/4" drill bit. Be sure to only drill through the hopper stand.

CAUTION: Do not bolt the ring bracket to the hopper wall or penetrate it in any way.

- Bolt the ring bracket to the hopper stand using the fasteners provided.




NOTE: Alternatively, the ring bracket may be installed on a wall or the side of a workbench.

- Slide the both hoses on the new fill line assembly (item 8) down through the ring bracket. Attach the air line on the fill assembly that came with your bucket attachment to the bottom port of the 3 way valve assembly.



- Attach the CPVC Tube (item 7) to the open end of the 1/2 clear tubing on your fill line assembly. Use clamp to secure (Item 3).



OPERATION

1. Invert or shake a bucket of dry chemical (not included) with the lid tightly sealed to fluff the chemical.
2. Remove the lid from the bucket. Insert the CPVC tube (item 7) into the bucket or an extinguisher that you may want to empty.
3. Turn the ball valve to point to the bottom air line.



4. Place the extinguisher to be filled on a scale. Insert the fill cone on the right side of the hopper snugly into the neck of the extinguisher. Tare the scale or note the empty weight.
5. Begin filling the extinguisher like you would normally. You may need to move the plastic tube (item 7) around in the dry chemical bucket to keep the chemical flowing.
6. When finished remove the plastic tube from the bucket of dry chemical and seal the bucket.
7. To fill from the hopper again, turn the ball valve to point at the top air line.

